

## WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

02-27-6

SW, NE, NE, NE, NW, NE, Sec. 34 T10N R21E

1. County OzaukeeTown ☐  
Village ☐  
City ☒Cedarburg

Check one and give name

2. Location 269' south of western Ave. and approx. 50' west of abandoned rapid  
Name of street and number of premise or Section, Town and Range numbers transverse line.3. Owner ☒ or Agent ☐ City of Cedarburg

Name of individual, partnership or firm

4. Mail Address Cedarburg, Wisconsin

Complete address required

5. From well to nearest: Building        ft; sewer        ft; drain        ft; septic tank        ft;  
dry well or filter bed        ft; abandoned well        ft.6. Well is intended to supply water for: Municipality

## 7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
24	0	17	15 1/4	703	1002
20	17	703			

## 8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
24	O.D. steel	0	17
16	steel	14"	130
16	steel	above 489	703

## 9. GROUT:

Kind	From (ft.)	To (ft.)
Neat cement	0	130

## 11. MISCELLANEOUS DATA:

Yield test: 16 Hrs. at 1000 GPM.Depth from surface to water-level: 69' 10" ft.Water-level when pumping: 127 ft.Water sample was sent to the state laboratory at:  
Will be sent upon permanent pump  
installation on 19       

## 10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Clay	0	17
Limestone	17	500
Shale	500	693
Limestone	693	912
Sandstone	912	1002

DNR permanent  
well # 83703

Construction of the well was completed on:

February 1956The well is terminated 18 inches  
☒ above, below ☐ the permanent ground surface.

Was the well disinfected upon completion?

Yes ☒ No ☐

Was the well sealed watertight upon completion?

Yes ☒ No ☐

LAYNE-NORTHWEST COMPANY

Signature [Signature]

TEL:eb

Registered Well Driller

Please do not write in space below

6005 W. Martin Drive, Milwaukee, Wis.

Complete Mail Address

Rec'd        No.       Ans'd       Interpretation       

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs.       48 hrs.       Confirm       B. Coli       Examiner       

CC: MADE FOR MUN. WATER FILE

Plot